

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAM: XTO ENERGY, INC
ADDRESS: 52260 WIK RD
KENAI, AK 99611
FACILITY: EAST FORELANDS
LOCATION: 60° 31' 10" N; 151° 20' 31" W

(2-16) (17-19)
AKG 31 5003 015
PERMIT NUMBER DISCHARGE NUMBER

☐ CHECK HERE IF NO DISCHARGE

MONITORING PERIOD


FROM	YEAR	MONTH	DAY	TO	YEAR	MONTH	DAY
	2009	1	1		2009	1	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)	

PARAMETER (32-37)		QUANTITY OR LOADING (46-53)			QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)				NO EX. (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		Average	Maximum	Units	Minimum	Average	Maximum	Units			
015 - Produced Water FLOW	Sample Measurement	0.100617097	0.240702	MGD	***	***	***	***	0	Weekly	Estimate
	Permit Requirement	***	***		***	***	***		***	Weekly	Estimate
015 - Produced Water PRODUCED SAND	Sample Measurement	***	***	***	No discharge	No discharge	No discharge	***	0	***	***
	Permit Requirement	***	***		No discharge	No discharge	No discharge		***	***	***
015 - Produced Water OIL & GREASE	Sample Measurement	***	***	***	***	6.75	7.9	mg/l	0	Weekly	Grab
	Permit Requirement	***	***		***	29	42		***	Weekly	Grab
015 - Produced Water pH	Sample Measurement	***	***	***	7.3	***	7.8	SU	0	Monthly	Grab
	Permit Requirement	***	***		6	***	9		***	Monthly	Grab
015 - Produced Water TAH	Sample Measurement	***	***	***	***	13.689	13.689	mg/l	0	Monthly	Grab
	Permit Requirement	***	***		***	24	32		***	Monthly	Grab
015 - Produced Water TAqH	Sample Measurement	***	***	***	***	13.876	13.876	mg/l	0	Monthly	Grab
	Permit Requirement	***	***		***	Report	Report		***	Monthly	Grab
015 - Produced Water TOTAL AMMONIA	Sample Measurement	***	***	***	5.1	5.1	5.1	mg/l	0	Quarterly	Grab
	Permit Requirement	***	***		Report	***	Report		***	Quarterly	Grab

NAME TITLE PRINCIPAL
EXECUTIVE OFFICER

Ryan Tunseth
HSE&T Coordinator

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


Signature

Telephone

907 776-2510

Date (YR/MO/DAY)

2/19/2009

COMMENTS & EXPLANATION OF ANY VIOLATIONS: WET Testing sampling frequency is reduced to once/6 months [Section II.G.6.a - Permit # AKG-31-5000] 1st Period 2009 WET tests were taken on 02/03/09 and will be reported on the Feb 09 DMR. Additionally the sampling frequency for TAH, TAqH, Copper, Manganese, Silver, Total Mercury, and Zinc is reduced from monthly to quarterly [Section II.G.6.a - Permit # AKG-31-5000] 1st Quarter 2009 sample results are shown.


**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

NAME: XTO ENERGY, INC
ADDRESS: 52260 WIK RD KENAI, AK 99611
FACILITY: EAST FORELANDS
LOCATION: 60° 31' 10" N; 151° 20' 31" W

(2-16) AKG 31 5003	(17-19) 015
PERMIT NUMBER	DISCHARGE NUMBER

<input type="checkbox"/>	CHECK HERE IF NO DISCHARGE
--------------------------	----------------------------

MONITORING PERIOD							
FROM	YEAR	MONTH	DAY	TO	YEAR	MONTH	DAY
	2009	1	1		2009	1	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)	

PARAMETER (32-37)		QUANTITY OR LOADING (46-53)			QUALITY OR CONCENTRATION (38-45)				NO EX. (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(54-61)	(46-53)	(54-61)	(38-45)	(46-53)	(54-61)				
		Average	Maximum	Units	Minimum	Average	Maximum	Units			
015 - Produced Water COPPER	Sample Measurement	***	***	***	***	4.11	4.11	ug/l	0	Monthly	Grab
	Permit Requirement	***	***	***	***	60	90	ug/l	***	Monthly	Grab
015 - Produced Water MERCURY	Sample Measurement	***	***	***	***	N/D	N/D	ug/l	0	Monthly	Grab
	Permit Requirement	***	***	***	***	0.5	0.8	ug/l	***	Monthly	Grab
015 - Produced Water MANGANESE	Sample Measurement	***	***	***	***	1.65	1.65	mg/l	0	Monthly	Grab
	Permit Requirement	***	***	***	***	7.9	15.8	mg/l	***	Monthly	Grab
015 - Produced Water SILVER	Sample Measurement	***	***	***	***	0.00	0	ug/l	0	Monthly	Grab
	Permit Requirement	***	***	***	***	46	149	ug/l	***	Monthly	Grab
015 - Produced Water ZINC	Sample Measurement	***	***	***	***	0.0493	0.0493	mg/l	0	Monthly	Grab
	Permit Requirement	***	***	***	***	3.1	6.1	mg/l	***	Monthly	Grab
015 - Produced Water WET - <i>Mytilus galloprovincialis</i> (invertibrate)	Sample Measurement	***	***	***	***	625	625	TUc	0	Quarterly	Grab
	Permit Requirement	***	***	***	***	1209	2425	TUc	***	Quarterly	Grab
NAME TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.					 Signature	Telephone	Date (YR/MO/DAY)			
Ryan Tunseth HSE&T Coordinator							907 776-2510	2/19/2009			
COMMENTS & EXPLANATION OF ANY VIOLATIONS: WET Testing sampling frequency is reduced to once/6 months [Section II.G.6.a - Permit # AKG-31-5000] 1st Period 2009 WET tests were taken on 02/03/09 and will be reported on the Feb 09 DMR. Additionally the sampling frequency for TAH, TAqH, Copper, Manganese, Silver, Total Mercury, and Zinc is reduced from monthly to quarterly [Section II.G.6.a - Permit # AKG-31-5000] 1st Quarter 2009 sample results are shown.											

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**


NAME: XTO ENERGY, INC
ADDRESS: 52260 WIK RD KENAI, AK 99611
FACILITY: EAST FORELANDS
LOCATION: 60° 31' 10" N; 151° 20' 31" W

(2-16) AKG 31 5003	(17-19) 015
PERMIT NUMBER	DISCHARGE NUMBER

<input type="checkbox"/>	CHECK HERE IF NO DISCHARGE
--------------------------	----------------------------

MONITORING PERIOD							
FROM	YEAR	MONTH	DAY	TO	YEAR	MONTH	DAY
	2009	1	1		2009	1	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)	

(32-37) PARAMETER		QUANTITY OR LOADING (46-)			QUALITY OR CONCENTRATION				NO EX. (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		53) (54-61) Average	Maximum	Units	(38-45) Minimum	(46-53) Average	(54-61) Maximum	Units			
015 - Produced Water WET -	Sample Measurement	***	***	***	***	***	***	TUc	0	Quarterly	Grab
	Permit Requirement	***	***		***	1209	2425		***	Quarterly	Grab
	Sample Measurement										
015 - Produced Water	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
015 - Produced Water	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
015 - Produced Water	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
015 - Produced Water	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
015 - Produced Water	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
015 - Produced Water	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
015 - Produced Water	Permit Requirement										

NAME TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Signature	Telephone	Date (YR/MO/DAY)
			907 776-2510	2/19/2009

COMMENTS & EXPLANATION OF ANY VIOLATIONS: WET Testing sampling frequency is reduced to once/6 months [Section II.G.6.a - Permit # AKG-31-5000] 1st Period 2009 WET tests were taken on 02/03/09 and will be reported on the Feb 09 DMR. Additionally the sampling frequency for TAH, TAqH, Copper, Manganese, Silver, Total Mercury, and Zinc is reduced from monthly to quarterly [Section II.G.6.a - Permit # AKG-31-5000] 1st Quarter 2009 sample results are shown.